



HAVE YOU ASSESSED THE RISK ASSOCIATED WITH THIS WORK? REPORT PROMPTLY ANY CONDITION LIABILE TO CAUSE AN ACCIDENT REMEMBER

YOU ARE RESPONSIBLE FOR YOUR SAFETY

**apa**  
 NATURAL GAS EMERGENCY  
 CONTACT NUMBER :  
**Ph. 1800 427 532**



**LOCALITY PLAN**  
 Brisbane UBD 233 - M17  
 APA GRID REF  
 NOT TO SCALE

**GAS RETICULATION**  
 FOR GAS MAINS TO BE INSTALLED IN A JOINT-USE TRENCH. REFER TO APA STANDARD DRAWING TR-001 FOR TRENCH PROFILE. ANY STAND ALONE AS PER IPSWICH CITY COUNCIL STANDARD DRAWINGS - SR-22 & SR 23. REFER TO APA STANDARD DRAWING TR-003 FOR TRENCH PROFILE.

ANY VARIATIONS TO THIS PLAN ARE TO BE APPROVED BY THE RESPONSIBLE APA DESIGNER.

CIVIL CONTRACTOR SHALL GIVE APA ONE WEEKS NOTICE BEFORE INSTALLATION OF ROAD CROSSING CONDUITS - EMAIL NOTICE TO APAScheduledWorks@apa.com.au

ELECTRICAL CONTRACTOR SHALL GIVE APA TWO WEEKS NOTICE BEFORE TRENCHING - EMAIL NOTICE TO APAScheduledWorks@apa.com.au

**REFERENCE DRAWINGS**  
 TRENCH SECTION - CONSTRUCTION - JOINT USE TRENCH ..... TR-001  
 ROAD RESERVE - FOOTPATH ONLY ..... TR-001  
 GAS SERVICE ALLOCATIONS - GENERAL CONSTRUCTION - CONDUITS & SERVICE ..... D-002  
 CONNECTION TEE - PE GAS MAINS ..... D-0023

**CONTACT DETAILS**  
 PHONE - 0477 398 905  
 EMAIL ADDRESS - APAScheduledWorks@apa.com.au

**LEGEND**

- PROPOSED PE GAS MAINS
- ROAD CROSSING CONDUIT
- PROPOSED STAND ALONE TRENCH
- PROPOSED COMMON TRENCH
- PROPOSED MAINS UNDER CONSTRUCTION
- EXISTING H.P STEEL PIPELINE
- EXISTING HIGH PRESSURE PIPELINE
- PROPOSED END CAP
- CONNECTION POINT TO EXISTING MAINS

**PIPE LENGTHS**  
 PROPOSED 40PE GAS MAIN - STAND ALONE TRENCH - Approx Length ..... 60 Meters  
 PROPOSED 40PE GAS MAIN - COMMON TRENCH - Approx Length ..... 20 Meters  
 TOTAL - PROPOSED 40PE GAS MAIN - Approx Length ..... 80 Meters

PROPOSED 63PE GAS MAIN - STAND ALONE TRENCH - Approx Length ..... 90 Meters  
 PROPOSED 63PE GAS MAIN - COMMON TRENCH - Approx Length ..... 180 Meters  
 TOTAL - PROPOSED 63PE GAS MAIN - Approx Length ..... 270 Meters

NUMBER OF ROAD CROSSINGS - 2 - Approx Length ..... 40 Meters  
 NUMBER OF TIE-IN POINTS - 2  
 NUMBER OF LOTS - 16

For Information Purposes Only

NOT FOR CONSTRUCTION

DATE PLOTTED: 10 April 2018 - 3:06pm

				<b>Australian Gas Networks</b> <b>apa</b>		NAME: A.POWELL		DATE: 09/11/17		<b>PROPOSED GAS RETICULATION</b>			
UPDATE TO DEVELOPERS LOT BOUNDARIES - NOT FOR CONSTRUCTION				10/04/18	JAG	P.H	CHECKED:		<b>PRELIMINARY ISSUE</b>				
PRELIMINARY ISSUE - NOT FOR CONSTRUCTION				21/11/17	AJP	GB	APPROVED:		<b>236-240 MONTEREA ROAD</b>				
DESCRIPTION				DATE	DRW	CHK	APP	PROJ No: 37215 410.03	MAXIMO No: 289719-16	SCALE: 1:500 @ A1	DRG No: <b>E28971916-01</b>	SHT: 1 of 1	REV: B